



CITY OF SUGAR LAND

**Request for
Temporary Utilities**

DATE: _____ APPLICATION #: _____

ADDRESS: _____

We, the general contractor and electrical contractor, request the use of temporary utilities for construction and the testing of equipment. We understand that the issuance of a permit for temporary utilities in no way grants permission to occupy or use any building, or portion thereof, unless all inspections for the building have been approved and a Certificate of Occupancy has been issued. We further understand that the temporary utilities may be disconnected for any violation of the Building Code. The general contractor and owner assume the responsibility for any violation of any city ordinance by a sub-contractor.

The temporary electrical permit will be in force for three (3) months (90 days). If more time is required to complete the building, a new application and fee shall be submitted by the electrical contractor.

The undersigned hereby agrees to indemnify and hold forever harmless the City of Sugar Land, its officers, and employees from any and all claims or causes of action alleged to have been caused directly or indirectly by the temporary use of utilities for which this application is made.

◆ ◆ ◆ ◆ ◆ **NOTE** ◆ ◆ ◆ ◆ ◆

A FINE OF UP TO \$200 PER DAY MAY BE ASSESSED IF A STRUCTURE IS OCCUPIED PRIOR TO THE ISSUANCE OF A CERTIFICATE OF OCCUPANCY BY THE CITY OF SUGAR LAND.

GENERAL CONTRACTOR:

MASTER ELECTRICIAN:

Signature

Signature

Print Name

Print Name

ELECTRICAL CODE

The City of Sugar Land has adopted the 2005 edition of the National Electrical Code with the following amendments:

1. No conductor smaller than No. 12 shall be used in a wiring system. This amendment to table 310-5.
2. Article 310-2 (b) Conductor Material. Conductors in this article shall be of copperclad aluminum, copper, or aluminum in sizes 1/0 or larger, unless otherwise stated.
3. The following regulations apply to underground installations:
 - (1) All conductors operating at fifty (50) volts or more shall be installed in conduit.
 - (2) Ridged nonmetallic conduit shall be limited to schedule 40 when below grade and schedule 80 when exposed to physical damage.

DOUBLE FEES

With respect to the electrical permit, where work is started or has proceeded prior to obtaining the applicable permit, the fees specified shall be doubled. Such doubled fees shall not relieve any person from fully complying with the requirements in the execution of the work nor from any other penalties prescribed in the code.